



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. SGHSSPS/2024 dated 02.05.2024
Issued to :- The Principal,
:- Sri Guru Harkrishan Sr. Sec. Public School,
:- Sector - 40 - C, Chandigarh
Quantity of sample :- Approximate 1200 ml.
Date of Collection :- 03-05-2024
Client reference :- Sample Collected by Laboratory Staff
Packing of sample :- Sample filled in P.P. and Glass Bottle
Source of sample :- from School tap of Sri Guru Harkrishan Sr. Sec. School,
Sector - 40 - C, Chandigarh


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	----	7.76
2	Odour	Agreeable	----	Agreeable
3	Taste	Agreeable	----	Agreeable
4	Turbidity	< 1.0	mg/l	0.8
5	Residual Chlorine	0.2 - 0.4	mg/l	0.3
6	Total Alkalinity (as CaCO ₃)	< 200	mg/l	92
7	Total Hardness (as CaCO ₃)	< 200	mg/l	80
8	Chloride (as Cl)	< 250	mg/l	04
9	Free & Saline Ammonia	Nil	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	136
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide receipt No.05/2024-25/191481, dated 02.05.2024, Amount Rs.3300/-

Note:- Water is fit for drinking

Lab No.- MCPHL/24/ 1670


Dated:- 06.05.2024



Chemist
M.C.P.H. Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh
Dated :-06.05.2024

Endst No. MCPH/24/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh with reference to your letter Endst No.MOH/Supdt. Admn/2024/5031 Dated 23.04.2024


Chemist
M.C.P.H. Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh